2000 1999 1998 1997

#### 18 PERFORMANCE MEASURES

Disclosure of financial performance measures and efficiency performance measures under regulation 15 of the Electricity (Information Disclosure) Regulations 1999 as amended by the Electricity (Information Disclosure) Amendment Regulations 2000.

# 1. Financial performance measures

(a) Return on funds	7.28%	5.94%	6.52%	4.31%			
(b) Return on equity	4.75%	4.76%	4.92%	2.93%			
(c) Return on investment	4.58%	6.84%	5.02%	2.74%			
2. Efficiency performance measures:							
(a) Direct line costs per kilometre	\$842	\$648	\$912	\$1,000			
Direct Expenditure System Length	\$1,586,594 1,885	\$1,212,783 1,871	\$1,693,385 1,856	\$1,851,501 1,851			
(b) Indirect line costs per electricity customer	\$52	\$66	\$58	\$60			
Indirect Expenditure Total consumers	\$1,022,052 19,824	\$1,302,298 19,612	\$1,150,773 19,872	\$1,185,438 19,706			

Disclosure of energy delivery efficiency performance measures under regulation 21 of the Electricity (Information Disclosure) Regulations 1999 as amended by the Electricity (Information Disclosure) Amendment Regulations 2000.

# 1. Energy Delivery efficiency performance measures:

(a)	Load factor (=a/b*c*100)	60.33	61.77	61.45	61.00
	<ul><li>a = kWh of electricity entering system</li><li>b = Maximum demand</li><li>c = Total number of hours in year</li></ul>	295,531,204 55,766 8,784	289,056,437 53,416 8,760	289,860,017 53,850 8,760	284,111,957 53,167 8,760
(b)	Loss ratio (=a/b*100)	6.69	6.15	6.31	6.41
	<ul><li>a = losses in electricity in kWh</li><li>b = kWh of electricity entering system</li></ul>	19,769,798 295,531,204	17,776,971 289,056,437	18,290,167 289,860,017	18,211,576 284,111,957
(c)	Capacity utilisation (=a/b*100)	37.29	36.20	33.16	33.00
	a = Maximum demand b = Transformer Capacity	55,766 149,534	53,416 147,549	53,850 162,374	53,167 161,093

		2000	1999	1998	1997	
2. Statistics						
(a)	System Length					
	Circuit Kilometres >11kV Circuit Kilometres 11kV Circuit Kilometres 400V	0 1,353 532	0 1,346 525	0 1,334 522	0 1,330 521	
	Total	1,885	1,871	1,856	1,851	
(b)	System Length - Overhead					
	Circuit Kilometres >11kV Circuit Kilometres 11kV Circuit Kilometres 400V	0 1,309 402	0 1,304 400	0 1,293 403	0 1,291 402	
	Total Overhead	1,711	1,704	1,696	1,693	
(c)	System Length - Underground					
	Circuit Kilometres >11kV	0	0	0	0	
	Circuit Kilometres 11kV Circuit Kilometres 400V	44 130	42 125	41 119	39 119	
	Total Underground	174	167	160	158	
(d)	Transformer Capacity (In Kilovolt Amperes)	149,534	147,549	162,374	161,093	
(e)	Maximum Demand	55,766	53,416	53,850	53,167	
(f)	Total electricity supplied from the system after losses (in Kilowatt Hours)	275,761,406	271,279,466	271,569,850	265,900,381	
(g)	g) Electricity conveyed for each retailer including losses.					
	Retailer 1 Retailer 2 Retailer 3 Retailer 4 Retailer 5 Retailer 6 Retailer 7 Retailer 8	233,114,409 2,270,947 2,001,871 57,031,511 19,249 249,926 434,399 408,892	233,540,531 * 17,224,124 * 1,001,773 * 37,290,009 *			
	* Restated to include losses.	295,531,204	289,056,437	289,860,017	284,111,957	
(h)	Total Customers	19,824	19,612	19,872	19,706	

		2000	1999	1998	1997
Disclosure of reliability performance measures under regulation 22 of the Electricity (Information Disclosure) Regulations 1999 as amended by the Electricity (Information Disclosure) Amendment Regulations 2000.					
1	Total number of interruptions				
	Class A - Planned - by Transpower Class B - Planned - by Line Owners Class C - Unplanned - by Line Owners Class D - Unplanned - by Transpower Class E - Unplanned - by ECNZ Class F - Unplanned - by other generation Class G - Any other loss of supply	0 223 107 2 0 0	0 217 149 0 0 0	0 249 117 1 0 0	0 234 156 2 0 0
	Total	332	366	367	392
2	Interruption targets for 2000 / 2001 Class B - Planned - by Line Owners Class C - Unplanned - by Line Owners Average interruption targets for 2000 / 2001 to	200 100 2004 / 2005 ve	aare		
3	Class B - Planned - by Line Owners	160	zais		
	Class C - Unplanned - by Line Owners	86			
4	Porportion of Class C interruptions not restored	•	•		
	3 Hours a = number of interruptions restored within 3	18% 19	17% 25		
	b = Total number of Class C interruptions	107	149		
	24 Hours	0%	0%		
	<ul><li>a = number of interruptions restored within 2</li><li>b = Total number of Class C interruptions</li></ul>	0 107	0 149		
5 (a)	(a) The total number of faults per 100 circuit kilometres of prescribed voltage electric line				
	11kV	7.91	11.07	8.77	11.73
(b)	Target for 2000 / 2001 year				
	11kV	7.39			
(c)	Average Target for 2000 / 2001 to 2004 / 2005	years			
	11kV	6.36			
6	The total number of faults per 100 circuit kilometres of underground prescribed voltage electric line				
	11kV	2.27	0.00	0.00	0.00
7	The total number of faults per 100 circuit kilometres of overhead prescribed voltage electric line				
	11kV	8.10	11.43	9.05	12.08
8	The SAIDI for the total number of interruption	300.44	242.23	255.21	353.09
9	SAIDI targets for 2000 / 2001				
	Class B - Planned - by Line Owners Class C - Unplanned - by Line Owners	64.00 132.00			

		2000	1999	1998	1997	
10	Average SAIDI target for 2000 / 2001 to 2004 / 2005 years					
	Class B - Planned - by Line Owners Class C - Unplanned - by Line Owners	53.40 100.20				
11	The SAIDI for the total number of interruptions within each interruption class					
	Class A - Planned - by Transpower Class B - Planned - by Line Owners Class C - Unplanned - by Line Owners Class D - Unplanned - by Transpower Class E - Unplanned - by ECNZ Class F - Unplanned - by other generation Class G - Any other loss of supply	0.00 94.14 199.49 6.81 0.00 0.00	0.00 80.81 161.42 0.00 0.00 0.00	0.00 99.97 153.62 1.62 0.00 0.00	0.00 96.26 231.76 25.07 0.00 0.00	
12	The SAIFI for the total number of interruption	3.99	3.24	3.39	5.78	
13	SAIFI targets for 2000 / 2001					
	Class B - Planned - by Line Owners Class C - Unplanned - by Line Owners	0.46 2.30				
14	Average SAIFI target for 2000 / 2001 to 2004 /	2005 years				
	Class B - Planned - by Line Owners Class C - Unplanned - by Line Owners	0.38 1.90				
15	The SAIFI for the total number of interruptions	within each inte	erruption class			
	Class A - Planned - by Transpower Class B - Planned - by Line Owners Class C - Unplanned - by Line Owners Class D - Unplanned - by Transpower Class E - Unplanned - by ECNZ Class F - Unplanned - by other generation Class G - Any other loss of supply	0.00 0.63 2.22 1.14 0.00 0.00 0.00	0.00 0.58 2.66 0.00 0.00 0.00	0.00 0.61 2.24 0.54 0.00 0.00	0.00 0.54 4.48 0.76 0.00 0.00	
16	The CAIDI for the total number of interruption	75	75	75	61	
17	CAIDI targets for 2000 / 2001					
	Class B - Planned - by Line Owners Class C - Unplanned - by Line Owners	139 57				
18	Average CAIDI Target for 2000 / 2001 to 2004					
	Class B - Planned - by Line Owners Class C - Unplanned - by Line Owners	140 52				
19	The CAIDI for the total number of interruptions within each interruption class					
	Class A - Planned - by Transpower Class B - Planned - by Line Owners Class C - Unplanned - by Line Owners Class D - Unplanned - by Transpower Class E - Unplanned - by ECNZ Class F - Unplanned - by other generation Class G - Any other loss of supply	0 150 90 6 0 0	0 140 61 0 0 0	0 163 69 3 0 0	0 180 52 33 0 0	